

Based upon low domestic risk and low commercial risk. Products certified to this level provide a level of resistance to opportunist attempts at forced entry, using bodily physical force and a limited range of hand tools, including those that create noise.

FIXING SUBSTRATE

- Timber (hardwood)
- Blockwork
- Brickwork/concrete blockwork
- Steelwork

TEST ATTACK TIME

- Maximum attack time: 1 minutes
- Maximum test duration: 10 minutes

TEST TOOLS USED

Tool Category A

- Adhesive tape
- Hooks
- 1 Glass Cutter
- Punches
- Rope
- Wire
- 1 Cable cutter - 150mm long
- Spanners - selection 150mm long
- Flexible plastic coupon
- Fishing line (e.g. polypropylene multi fibre)
- Hexagon wrenches - selection 120mm long
- Hooks
- 1 Knife - blade 125mm long x 3 mm thick
- 1 Lever - 0.7 kg/300mm long
- Pliers (including self gripping) - selection 200mm long
- 1 Screwdriver - 6.5mm diameter/square x 150mm long Self - tapping screws
- Tweezers
- WD40
- Wood/plastic wedges