

Based on a medium commercial risk. Products certified to this level provide resistance to experienced determined attempts at forced entry using a wide range of hand tools and battery power tools, with a disregard for noise created.

## FIXING SUBSTRATE

- Reinforced brickwork
- Reinforced concrete
- Steelwork

## TEST ATTACK TIME

- Maximum attack time: 10 minutes
- Maximum test duration: 30 minutes

## TEST TOOLS USED

### Tool Category D (Category A, B and C plus)

- 1 Jigsaw, cordless – 12 V d.c. with 3 HSS / HSCO / Carbide blades, complete with one spare power pack
- 1 Disc grinder, cordless – 12 V d.c. with 3 cutting discs
- 1 Drill cordless with rotary action only – 12 V d.c., with one spare power pack
- 5 Drill bits (13mm diameter jobber – HSS / HSCO / Carbide)
- 1 Felling/fire axe – 850mm long / 3 kg
- 1 Hooligan bar – 760mm long
- 1 Sledgehammer – 900mm long/3 kg
- 1 'A-tool' lock puller – 500mm long
- 1 Bolt cutters – 500mm long
- 1 General purpose saw – 750mm long
- 1 Hole saw – 50mm diameter
- 1 'K-tool' lock remover
- 1 Plate shears – 300mm long
- Steel wedges – 150mm long
- 1 Tube – 75mm diameter x 500mm long